

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

PV 50633514 0001

Berichtsnummer Report No.:

CN240NTU 001

Genehmigungsinhaber License Holder:

Ningbo Osda Solar Co., Ltd.
1-1, No.136, Haichuan Road, Jiangbei Area,
Ningbo City,
315000 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Site:

2 Fertigungsstätten auf Folgeseiten
Listing of 2 factories on following pages

Prüfzeichen Test Mark:


Gepprüft nach Tested according to:

IEC 61215-1:2021
IEC 61215-1-1:2021
IEC 61215-2:2021
IEC 61730-1:2023
IEC 61730-2:2023
EN IEC 61215-1:2021
EN IEC 61215-1-1:2021
EN IEC 61215-2:2021
EN IEC 61730-1:2018
EN IEC 61730-2:2018

Geräteidentifikation
Product Identification
Produkt: PV Module

Product:
Modell: Modelle sind auf nächste(r) Seite(n) gelistet
Type: *Type designation(s) are listed on the next page(s)*
Technische Daten: Class II acc. to IEC 61140
Technical Data: For other ratings, refer to the test report

Gültig bis: 2029-06-04
Date of expiry:
Gültig ab: 2024-06-18
Valid from:
Ausstellungsdatum: 2024-06-18
Date of issue:
Zertifizierungsstelle:
Certification body:


 Dipl.-Ing. (FH) Matthias Grzam

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

PV 50633514 0001

Berichtsnummer *Report No.:*

CN240NTU 001

Produkt *Product:* PV Module

Modell *Type:*

Bezeichnung *Designation:*

New model types:

Max. system voltage (Up to 1500VDC)

With ½ cut of mono Perc c-Si cells:

ODAxXX-33V-MHP, ODAxxx-33V-MHBP

(xxx = 645-670, in steps of 5, 132 cells)

ODAxXX-30V-MHP, ODAxxx-30V-MHBP

(xxx = 585-610, in steps of 5, 120 cells)

ODAxXX-28V-MHP, ODAxxx-28V-MHBP

(xxx = 530-555, in steps of 5, 110 cells)

ODAxXX-25V-MHP, ODAxxx-25V-MHBP

(xxx = 490-505, in steps of 5, 100 cells)

With ½ cut of Topcon c-Si cells:

ODAxXX-33V-MH, ODAxxx-33V-MHB

(xxx = 670-700, in steps of 5, 132 cells)

ODAxXX-30V-MH, ODAxxx-30V-MHB

(xxx = 610-635, in steps of 5, 120 cells)

ODAxXX-28V-MH, ODAxxx-28V-MHB

(xxx = 560-580, in steps of 5, 110 cells)

ODAxXX-25V-MH, ODAxxx-25V-MHB

(xxx = 510-530, in steps of 5, 100 cells)

ODAxXX-39V-MH, ODAxxx-39V-MHB

(xxx = 590-620, in steps of 5, 156 cells)

ODAxXX-36V-MH, ODAxxx-36V-MHB

(xxx = 550-590, in steps of 5, 144 cells)

ODAxXX-33V-MH, ODAxxx-33V-MHB

(xxx = 500-540, in steps of 5, 132 cells)

ODAxXX-30V-MH, ODAxxx-30V-MHB

(xxx = 460-490, in steps of 5, 120 cells)

ODAxXX-27V-MH, ODAxxx-27V-MHB

(xxx = 410-440, in steps of 5, 108 cells)

xxx represents output power in Wp

Remarks:

Fire Rating: Class C (according to UL 790)

Design Load/Safety Factors: 3600 Pa / 1.5 (downward)

1600 Pa / 1.5 (upward)

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.



Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

PV 50633514 0001

Berichtsnummer *Report No.:*

CN240NTU 001

Produkt *Product:*

PV Module

Fertigungsstätten *Factories:*

- 1 Ningbo Osda Solar Co., Ltd.
1-1, No.136, Haichuan Road, Jiangbei Area,
Ningbo City,
315000 Zhejiang
P.R. China
- 2 Shandong Oushengda New Energy Co., Ltd.
Intersection of Guanzhuang
Middle Road and Aeon South
Road, Zhengwang Town, Hedong District,
Linyi City
276028 Shandong
P.R. China

